

## SPECIFICATION



Certification	UL\CUL LISTED File No.:E504391
Desc	20 Amp Self-Test GFCI Outlet
Feature	Self-Test GFCI Outlet
Rating	20A 125V AC 60Hz
NEMA	5-20R
Trip Lever	4mA~6mA within 25ms
Operation Temp	-35°C to 66°C
Grounding	Self-Grounding with Extend Copper Clip
Status	Dual LED Indicators Green and Red
Surge Withstand	3KA 6KV
Tamper-Resistant TR	
Standard Version	
	UL498 UL1998 UL943 Fifth Edition 2018 Version

