

conductor 导体

PVC insulation PVC 绝缘

RVV 系列



芯数×截面 Core Num.×Nom.Are a mm ²	导体结构根/直 径 Conductor Structure Bar/Diameter mm	绝缘 Insulating mm		外护套 External Sheath mm		参考外径 Referential External Diameter mm
		最薄厚度 Thinnest Thickness	标称厚度 Nominal Thickness	最薄厚度 Thinnest Thickness	标称厚度 Nominal Thickness	
2×0.5	28/0.20	0.35	0.5	0.41	0.6	5.4
2×0.75	42/0.20	0.35	0.5	0.41	0.6	6.1
2×1	32/0.20	0.44	0.6	0.58	0.8	6.7
2×1.5	48/0.25	0.53	0.7	0.58	0.8	7.7
2×2.5	77/0.25	0.62	0.8	0.75	1	9.2
2×4	56/0.30	0.62	0.8	0.75	1	10.7
2×6	84/0.30	0.62	0.8	0.75	1	11.8
3×0.5	28/0.20	0.35	0.5	0.41	0.6	5.7
3×0.75	42/0.20	0.44	0.6	0.58	0.8	6.8
3×1	32/0.20	0.44	0.6	0.58	0.8	7
3×1.5	48/0.25	0.53	0.7	0.67	0.9	8.3
3×2.5	77/0.25	0.62	0.8	0.75	1	9.7
3×4	56/0.30	0.62	0.8	0.75	1	11.3
3×6	84/0.30	0.62	0.8	0.75	1	12.5
4×0.5	28/0.20	0.35	0.5	0.58	0.8	6.6
4×0.75	42/0.20	0.44	0.6	0.58	0.8	7.4
4×1	32/0.20	0.44	0.6	0.67	0.9	7.9
4×1.5	48/0.25	0.53	0.7	0.75	1	9.3
4×2.5	77/0.25	0.62	0.8	0.84	1.1	10.8
4×4	56/0.30	0.62	0.8	0.84	1.1	12.6
4×6	84/0.30	0.62	0.8	0.84	1.1	13.9
5×0.5	28/0.20	0.35	0.5	0.58	0.8	7.2
5×0.75	42/0.20	0.44	0.6	0.67	0.9	8.3
5×1	32/0.20	0.44	0.6	0.67	0.9	8.6
5×1.5	48/0.25	0.53	0.7	0.84	1.1	10.3
5×2.5	77/0.25	0.62	0.8	0.92	1.2	12
5×4	56/0.30	0.62	0.8	0.92	1.2	14
5×6	84/0.30	0.62	0.8	0.92	1.2	15.5
6×0.5	28/0.20	0.35	0.5	0.58	0.8	7.8
6×0.75	42/0.20	0.44	0.6	0.67	0.9	9
6×1	32/0.20	0.44	0.6	0.67	0.9	9.3
6×1.5	48/0.25	0.53	0.7	0.84	1.1	11.2
6×2.5	77/0.25	0.62	0.8	0.92	1.2	13.1
6×4	56/0.30	0.62	0.8	0.92	1.2	15.3
6×6	84/0.30	0.62	0.8	0.92	1.2	17