

序号 No.	检验项目 INSPECTION ITEMS	技术要求 technical requirements	检验结果 inspection result	单项判定 Item conclusion
7	密度, g/cm ³ Density	0.65~0.80 (允许 偏差为±10%)	0.88	合格 qualified
8	板内密度偏差, % Internal deviation of board density	±10.0	2.6	合格 qualified
9	含水率, % moisture content	3.0~13.0	5.1	合格 qualified
10	静曲强度, MPa static bending intensity	≥30.0	60.6	合格 qualified
11	弹性模量, MPa elasticity modulus	≥2800	5640	合格 qualified
12	吸水厚度膨胀率, % Water absorption and thickness swelling	≤45.0	25.3	合格 qualified
13	内结合强度, MPa internal bond strength	≥0.60	1.08	合格 qualified
14	表面结合强度, MPa surface bonding strength	≥0.60	0.95	合格 qualified
15	甲醛释放量, mg/m ³ Formaldehyde Emission	E ₁ ≤0.124	0.037 (56h)	合格 qualified